

The applicant: **SIRPI S.p.A**
VIA CASINO D'ALBERI, 19
IT- 20067 TRIBIANO
Milano

is authorized to place the label "Classification of Reaction to Fire of Construction Products " according to the report N° 2018AN2954



aitex
textile research institute

**CLASSIFICATION OF REACTION TO FIRE OF:
CONSTRUCTION PRODUCTS**

N° 18AN2954

The sample reference:

“ENF”

has been tested according to the standards EN ISO 11925-2:2010 and EN 13823:2010+A1:2014. The classification according to standard EN 13501-1:2007+A1:2009 is:

“B-s1,d0”

Alcoy, October 8th 2018.

Celia Dolça
HEAD OF FIRE BEHAVIOUR LAB.

