

The applicant: **SIRPI S.p.A**  
VIA CASINO D'ALBERI, 19  
IT- 20067 TRIBIANO  
Milano

is authorized to place the label "Classification of Reaction to Fire of Construction Products " according to the report N° 2018AN3281



**aitex**  
textile research institute

**CLASSIFICATION OF REACTION TO FIRE OF:  
CONSTRUCTION PRODUCTS**

**N° 18AN3281**

The range:

**“EW”**

has been tested according to the standards EN ISO 11925-2:2010 and EN 13823:2010+A1:2014. The classification according to standard EN 13501-1:2007+A1:2009 is:

**“B-s2,d0”**

Alcoy, November 09th 2018.

---

**Celia Dolça**  
HEAD OF FIRE BEHAVIOUR LAB.

